CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3240-0328:151 Page 1 of 1

CATEGORY: Duct Smoke Detector Housing/Base Unit

LISTEE: Potter, 2081 Craig Road, St. Louis MO 63146

Contact: Brad Serangeli (314) 878-4321

DESIGN: Models DSD-I, DSD-P, ADSD-P and ADSD-PR duct smoke detector units. Each unit

consists of a smoke detector head. The smoke detector heads are not suitable for use as

open area detection. Refer to listee's data sheet for additional detailed product

description and operational considerations.

RATING: 120 VAC, 230 VAC, 24 VAC and 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances

and in a manner acceptable to the authority having jurisdiction.

Listee's name, model designation, electrical rating and UL label. MARKING:

APPROVAL: Listed as duct smoke detector units for use with separately listed compatible fire alarm

> control units to detect an abnormal amount of smoke density in the return air ducts of air conditioning and ventilating system. The air velocity in the duct shall be between 300-

4000 fpm.

For duct application only. Not suitable for open area protection. NOTE:

XLF: 3240-0410:155

09-11-2001



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

JUNE 20, 2002 Date Issued: Listing Expires June 30, 2003

DIANE K. AREND, Senior Deputy Authorized By:

Program Manager